

## SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01/2025Dated: 06/05/2025

It is certified that an inspection team headed by Dr. Lekha Badodekar (Medical Officer) from P.H.C. Salai Godhani inspected the Suyash Public School situated at Survey No. 28/B, Plot No. 50, Mouja : Hudkeshwar, Nagpur on 06/05/2025 and on the basis of Water Test Report (Attached) bearing No. 98 W.Q. Lab Level-II/NAG/2023 dated 05/05/2025 of Water Quality Lab Level – II, Hydrology Project, Jalvigyan Bhavan, Vainganga Nagar, Aini, Nagpur (PHED Lab) certified that the Suyash Public School, Survey No. 28/B, Plot No. 50, Mouja : Hudkeshwar, Nagpur has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 05/05/2026

Signature with Seal: .....

Name : Dr. Lekha BadodekarDesignation : Medical Officer

Name &amp; Address of the Office /

Department : P.H.C. Salai Godhani

To,

The Principal,  
Suyash Public School  
Survey No. 28/B, Plot No. 50,  
Mouja : Hudkeshwar, Nagpur

MANAGER

Suyash Public School  
Hudkeshwar, Nagpur-34

PRINCIPAL

Suyash Public School  
Hudkeshwar, Nagpur,



R. No. RQ91/5633

1st Vidnyan Bhavan, Wainganga Nagar, Ajni Nagpur - 440003.

**Government of Maharashtra**  
Water Resources Department



Hydrology Project Division, Nagpur,  
Water Quality Lab Level-II, Nagpur.

**AN ISO 9001: 2015 CERTIFIED LABORATORY**

No. <b>98</b> W.Q.LAB LEVEL-II/NAG/2023		Date: <b>05/05/2025</b>	
<b>Sample Analysis Report</b>			
Name and Address of Client: Suyash Public School 50, New Om Nagar, Rotkar Layout, Hudkeshwar Road, Nagpur.		Date of Sampling	02/05/2025
		Sample Collected by	Client
		Date of Sample receipt in Lab	02/05/2025
		Sample I.D. Number	DW/2505/001
Reference	Your letter dated: <b>02/05/2025</b>		
Sample Description	<b>RO Water Sample</b>		

Sr. No.	Characteristic (Parameter)	Unit	Analysis Result	DRINKING WATER - SPECIFICATION BIS 2012 IS 10500 : 2012	
				Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
1	Colour	Hazen unit	<1	5 Max	15 Max
2	Odour	--	Agreeable	Agreeable	Agreeable
3	pH	--	7.8	6.5 To 8.5	No relaxation
4	Turbidity	NTU	0.1	1 Max	5 Max
5	Total Dissolved Solids	mg/L	90	500 Max	2000 Max
6	Total Alkalinity (as CaCO <sub>3</sub> )	mg/L	62	200 Max	600 Max
7	Chloride (as Cl )	mg/L	10.0	250 Max	1000 Max
8	Total Hardness (as CaCO <sub>3</sub> )	mg/L	68	200 Max	600 Max
9	Calcium (as Ca)	mg/L	17.6	75 Max	200 Max
10	Magnesium (as Mg)	mg/L	5.8	30 Max	100 Max
11	Fluoride (as F)	mg/L	0.06	1.0 Max	1.5 Max
12	Sulphate (as SO <sub>4</sub> )	mg/L	8.2	200 Max	400 Max
13	Nitrate (as NO <sub>3</sub> )	mg/L	0.92	45 Max	No relaxation
14	Iron (as Fe)	mg/L	0.05	0.3 Max	No relaxation
15	Total coliforms	MPN/100ml	Absent	Shall not be detectable in any 100 ml sample	
16	Faecal coliforms	MPN/100ml	Absent	Shall not be detectable in any 100 ml sample	

End of Report



*Sensus*  
**Government Analyst**  
Water Quality Lab Level-II  
Hydrology Project, Jalvigyan Bhavan,  
Wainganga Nagar, Ajni,  
NAGPUR

*Manish*  
**MANAGER**  
Suyash Public School  
Hudkeshwar, Nagpur-34

*Prapsc*  
**PRINCIPAL**  
Suyash Public School  
Hudkeshwar, Nagpur.